




Download

DXF 2D - 1885.dxf 3DS disano 1885 rodio.3ds 3DM disano 1885 rodio.3dm Montaggi - rodio 06-20.pdf BIM - 1885 Rodio LED HT - asymmetric -20200528.zip





1885 Rodio LED HT - asymmetric

Housing: in die-cast aluminium with cooling fins

Reflector: with asymmetric beam options, made in polycarbonate with highefficiency PVD metal surface finishing.

Diffuser: 5mm thick tempered glass, resistant to thermal shocks and impacts. Coating: the standard powder coating consists of a first metal surface pretreatment stage and of single layer of UV-stabilised, corrosion and salt resistant polyester powder coating.

Equipment: external connector for quick installation. Silicone rubber gasket; external screws and bolts in stainless steel; air recirculation valve. Electronic safety device to protect the LED module and the related ballast compliant with EN 61547. It works in two modes: - differential mode: surge between power cables and between the phase and neutral. - common mode: surge between cables and between the phase and neutral. - common mode: surge between power, L/N and ground cables or between the fixture's body if it is of class II and installed on a metal pole. Upon request: protection up to 10KV. Peinture conforme à la norme NF EN ISO 9227 - Essais de corrosion en atmosphères artificielles, pour atmosphères agressives. Power factor: >= 0.9 Luminous flux maintenance 80%: 80000h (L80B20) - Ta = -40°C ÷ +50° Wind curéace L-200er2 €:1420cm2

Wind surface: L:390cm² F:1420cm²

The fixtures can be equipped with a two-level dimming system that can be preset and based on the calculation of the virtual midnight. The device is embedded directly into the device and does not require the installer to update the system. The dimming of the luminous flux occurs without a drive cable or a control phase.

The average value between the time the lighting fixture is turned on (sunset) and turned off (dawn) is the reference point for the device, and is called "natural midnight". A microprocessor will calculate the desired switching time starting from this base value. Factory settings are 3 hours before the "natural midnight" (approximately 10 pm) and 4 hours after it (approximately 5 am). Factory settings may be changed upon special requests.

Code	Gear	Kg	Lumen Output-K-CRI	WTot	Colour	Surge
414750-00	CLD	6.35	LED-5134lm-4000K-CRI 70	51 W	GRAPHITE	6/8kV



333 pole mounting diam.60

1920

- 334 pole mounting diam. 76

350 protection guard

The reported luminous flux is the flux emitted by the light source with a tolerance of ± 10% compared to the indicated value. The W tot column indicates the total wattage absorbed by the system without exceeding 10% of the indicated