



Download



341 Troubleshooting

Device to be installed on each light source during manufacture. NOTE: use subcode 66 to order fixtures complete with troubleshooting devices . Price on request. (AD-1)Troubleshooting: Control unit to perform local tests . By connecting various AD-1 modules (max 200) to the control unit you can create a centralised system. Max. distance from the control unit: 500 metres.

Code	Kg	WTot	Colour
986551-00	0,05	0 W	WHITE

Prodotti



- 614 Safety permanent 1 hr

The reported luminous flux is the flux emitted by the light source with a tolerance of $\pm 10\%$ compared to the indicated value. The W tot column indicates the total wattage absorbed by the system without exceeding 10% of the indicated